



2426


Metlab UK Ltd, Dewar Place, Kirkton Industrial Estate, Arbroath, DD11 3LS
Tel: 01241 871225 Fax: 01241 876251

Test Certificate

Client: Ductmate (Europe) Ltd. Arrol Road Wester Gourdie Industrial Estate Dundee DD2 4TH	Certificate No.: C6101801 Customer Order No.: 49097 Date Received.: 18 th October 2006 Test Date: 28 th October 2006 Page: 1 of 1	Issue.: 1
Test: Tensile Test. Product: CL20 Clutcher System	Specification: Based on ASTM E8M 04 / BS EN 10002-1:2001	

Clutcher Working Load		Fixture Diameter	Wire Rope	Break Load			Failure Mode
lbs	kg			N	kg	lbs	
250	113	1"	WR20	8629	880	1940	Wire
250	113	1"	WR20	8651	882	1945	Wire
250	113	1"	WR20	8651	882	1945	Wire
250	113	1"	WR20	8451	862	1900	Wire
250	113	1"	WR20	8051	821	1810	Wire

End of Test Certificate

Signed:  Quality Manager Date: 6 th November 2006 For METLAB UK Ltd.	Tested by: M.Shepherd Witnessed by: N/A
---	--