



**REPORT ON THE TESTING OF
CIRCULAR DUCT SANDWICH
ACCESS DOORS TO DW144
LEAKAGE RATES**

**Report 15653/2
December 2000**

Carried out for:
**Ductmate (Europe) Ltd.
Arrol Road
Wester Gourdie Industrial Estate
Dundee
DD2 4TH**

Compiled by:
PJ Heywood



No. of pages: ii of preamble
2 of text

Appendix A1
Appendix B1

This report must not be reproduced except in full without the written approval of an executive director of BSRIA

SUMMARY

Three Ductmate circular duct sandwich access doors, Types A, B, and C, showed no discernible leakage when installed in accordance with the manufacturer's instructions in a circular duct and tested to DW 144 at pressures of 2000 Pa and -750 Pa.

Circular sandwich type access doors.

Access door size	Test Pressure	Leakage rate
mm	Pa	l/s
Type A	2000	0.0
	-750	0.0
Type B	2000	0.0
	-750	0.0
Type C	2000	0.0
	-750	0.0

Schematic of circular duct sandwich type access door.

