



**REPORT ON THE TESTING OF
RECTANGULAR DUCT SANDWICH
ACCESS DOORS TO DW144
LEAKAGE RATES**

**Report 15653/3
December 2000**

Carried out for:
**Ductmate (Europe) Ltd.
Arrol Road
Wester Gourdie Industrial Estate
Dundee
DD2 4TH**

Compiled by:
PJ Heywood



No. of pages: ii of preamble
2 of text
Appendix A1
Appendix B1

This report must not be reproduced except in full without the written approval of an executive director of BSRIA

SUMMARY

Three Ductmate sandwich access doors for rectangular ducts, Type 106, Type 128, and Type 1814, showed no discernible leakage when installed in accordance with the manufacturers instructions in a rectangular duct and tested to DW144 at pressures of 2000 Pa and -750 Pa.

Rectangular duct sandwich Access Doors.

Access door size	Test Pressure	Leakage rate
mm	Pa	l/s
Type 106	2000	0.0
	-750	0.0
Type 128	2000	0.0
	-750	0.0
Type 1814	2000	0.0
	-750	0.0

Schematic of rectangular duct sandwich access door

